


NOTE: ALL SLAB AND CRAWL SPACE CONNECTIONS MUST BE A MINIMUM OF 3" BELOW THE FOOTER AND EXIT THE BUILDING AT THE FRONT OF THE STRUCTURE TO PROVIDE THE SHORTEST, MOST DIRECT ROUTE FROM THE BUILDING TO THE EXISTING LATERAL STUB.



## CLEANOUT TYPE 1

(ONLY LANDSCAPED SURFACES WITHIN THREE FEET OF BUILDING)

### TYPE 1 CLEANOUT DETAIL